

Isleta Eastside

Consumer Confidence Report, 2024

(PWS ID #063501109)

Release Date: June 2025

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA) for calendar year 2024. This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Lead Service Line Inventory is on-going.

The Pueblo of Isleta is continually working on updating the Lead Service Line Inventory. For the Eastside water system, the Pueblo has information on what type of service line, or piping, was utilized to connect the water main line to the shut-off device located on your property. The Public Works Department is continuing to research what type of water line was used to connect from the shut-off device to your home. There are 482 water connections, of which 233 are non-lead and 249 are unknown.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Your water is provided by two wells located nearby the Casino area. There is an Arsenic treatment facility and chlorine disinfection at the well house.

Source water assessment and its availability.

A Source Water Assessment Report is available for the Eastside water system. To view a copy of the report, please call the Public Works office at 505-869-5170. Based on the factors discussed in the report, the Eastside water system was determined to have a MEDIUM susceptibility to contamination.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity including:

- Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Tribal Members are welcome to contact Public Works (505-869-5170) with any questions, comments or concerns.

Description of Water Treatment Process

Your water is treated by filtration and disinfection. Filtration removes particles suspended in the source water. Particles typically include clays and silts, natural organic matter, iron and manganese, and microorganisms. Disinfection involves the addition of chlorine or other disinfectants to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5-minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and ensuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below, please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's

Adopt Your Watershed to locate groups in your community or visit the Watershed Information Network's How to Start a Watershed Team.

- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Who Do I Contact with Questions or Comments?

Please contact Mr. Edwin Jaramillo, Director of Public Works with any questions or comments you may have regarding this report. His phone number is 505-869-5170 and his email is: Edwin.Jaramillo@isletapueblo.com

Additional Information for Lead

The Eastside water system inventory does not include any known lead service lines. The Pueblo of Isleta researched all available records on the types of service lines installed at each building on the Eastside water system. Some homeowners provided information on what type of service line they have from the water shut-off to the homes; others stated they did not know what type of service line is installed. Public Works will be continually working on this inventory to gain information on what type of piping is installed from the shut-off to the home. There are currently 249 unknown service lines from the shut-off to the buildings and 233 service lines that we know what they are constructed of (PVC, poly, copper, galvanized). Customers will be notified once their unknown service lines are identified.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ISLETA EASTSIDE is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact ISLETA EASTSIDE (Public Water system Id: 063501109) by calling 505-869-9781 or emailing Edwin.Jaramillo@isletapueblo.com. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Information for Arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Water Quality Data Tables

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report.

The EPA requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Detected Regulated Contaminants

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sampl e Date	Violati on	Typical Source
				Lo w	Hig h			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (mg/l)	4	4	1.51	1.24	1.73	2024	No	Drinking water additive used for disinfection
TTHMs [Total Trihalomethanes] (ppb)	No goal for Total	80	2.7	NA	NA	2024	No	By-product of drinking water disinfection
Inorganic Contaminants								
Arsenic (ppb)	0	10	5.8 (AVG)	4.2	8.5	2024	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Sodium (ppm) (NR)	N/A	N/A	71	N/A	N/A	2023	No	Erosion of natural deposits; Leaching
Radioactive Contaminants								

Contaminants		MCLG or MRDLG		MCL, TT, or MRDL	Detect In Your Water	Range		Sampl e Date	Violati on	Typical Source
						Lo w	Hig h			
Beta/photon emitters (pCi/L)		0		50	3.37	NA	NA	2024	No	Decay of natural and man-made deposits.
Uranium (ppb)		0		30	1.2	NA	NA	2024	No	Erosion of natural deposits
Contaminants			Your Water	Range		# Samples Exceeding AL	Sample Date	Exceeds AL	Typical Source	
				Low	High					
Inorganic Contaminants										
Copper - action level at consumer taps (ppm)	1.3	1.3	0.33	0.008	0.4	0	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	1.1	NA	1.1	0	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Violations and Exceedances

There were no violations to report for the calendar year 2024.

Additional Contaminants

The Pueblo participated in UCMR5 sampling in March of 2025. The UCMR5's tested for PFAS, PFOS, PFHxS, HFPO-DA, PFNA, PFBS and Lithium. The analytical results for Lithium are shown below. The results for PFAS, PFOS, PFHxS, HFPO-DA, PFNA, and PFBS were all below the Maximum Contaminant Level (MCL) and Minimum Reporting Level (MRL) as defined by EPA.

The Pueblo is required to report to customers the availability of the results for these samples within 12 months after they are known, which is why we are including the results in this report. The Pueblo will do a second series of UCMR5 samples in the fall of 2025. Those results will be included in the 2026 Water Quality Report.

Contaminants	State MCL	Your Water	Violation	Explanation and Comment
Lithium	NA	85 ug/L	No	Lithium was detected in the UCMR5 sampling the Pueblo did in March 2025. We are required to report this detection to you within six months of learning the results. No other contaminants were reported.

Undetected Contaminants

The following contaminants were monitored for, but were not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
Alpha emitters (pCi/L)	0	15	ND	No	Erosion of natural deposits
Halo acetic Acids (HAA5) (ppb)	NA	60	ND	No	By-product of drinking water chlorination
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	ND	No	Erosion of natural deposits
Total Coliform Bacteria (monthly samples)	0	1	ND	No	Naturally present in the environment

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
mg/L	mg/L: Number of milligrams of substance in one liter of water
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
mrem/yr	mrem/yr: millirems per year (a measure of radiation absorbed by the body)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Important Drinking Water Definitions	
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
90th Percentile	Compliance with the lead and copper action levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected.

For more information please contact:

Contact Name: Edwin Jaramillo, Director of Public Works
Address: P.O. Box 1270
Isleta, NM 87022
Phone: 505-869-5170